

Packaged Terminal Air Conditioning and Heat Pumps

Must have an EER rating of greater than: 12.8 - (.213 x (BTUH / 1000))

| Measure | Rebate |
|----------|--------|
| Any size | \$50 |

Unitary and Split System Air Conditioning

| Measure | Rebate | Efficiency |
|------------------------|----------|------------|
| < 65,000 BTUH | \$40/ton | 13.0 EER |
| 65,000 – 135,000 BTUH | \$40/ton | 11.0 EER |
| 136,000 – 240,000 BTUH | \$40/ton | 10.8 EER |
| 241,000 – 760,000 BTUH | \$40/ton | 10.0 EER |
| > 760,000 BTUH | \$40/ton | 9.7 EER |

Air Source Heat Pumps

| Measure | Rebate | Efficiency |
|----------------------------|----------|------------|
| < 65,000 BTUH (split) | \$40/ton | 14.0 SEER |
| < 65,000 BTUH (single pkg) | \$40/ton | 14.0 SEER |
| 65,000 – 135,000 BTUH | \$40/ton | 11.0 EER |
| 136,000 – 240,000 BTUH | \$40/ton | 10.8 EER |
| > 240,000 BTUH | \$40/ton | 10.0 EER |

Water Source Heat Pumps

| Measure | Rebate | Efficiency |
|-----------------------|----------|------------|
| < 240,000 BTUH @ 85°F | \$40/ton | 14.0 EER |

Air Cooled Chillers

| Measure | Rebate | Efficiency |
|----------|----------|----------------------|
| Any size | \$40/ton | 1.2 KW/ton full load |

Water Cooled Chillers

| Measure | Rebate | Efficiency |
|---------------|----------|--|
| < 150 ton | \$20/ton | .78 KW/ton full load .49 KW/ton part load |
| 150 – 300 ton | \$40/ton | .63 KW/ton full load .44 KW/ton part load |
| > 300 ton | \$40/ton | .58 KW/ton full load .44 KW/ton part load |

Heat Pump Water Heaters

| Measure | Rebate | Efficiency |
|----------------------|---------|------------|
| < 80 gallon tank | \$1,000 | 3.0 COP |
| 80 – 150 gallon tank | \$2,000 | 3.0 COP |
| > 150 gallon tank | \$2,500 | 3.0 COP |



Other

- VFDs are for use with supply fans, return fans, exhaust fans, water pumps and cooling tower pumps only.
- Air economizers must be installed on CEE Tier 1 or higher efficiency units.

| Measure | Rebate | Efficiency |
|---|---------------|--|
| Variable frequency drives up to 50 HP | \$40/hp | |
| Outside air economizer using two enthalpy sensors | \$250 | |
| Energy recovery ventilation (ERV) with a minimum of 450 CFM and as part of an electric-powered system | \$1/CFM | ARI 1060 rating > 65% winter effectiveness |
| Programmable setback thermostat | \$35 | |
| HVAC occupancy sensor | \$60 | |

For More Information

For more information and an up-to-date list of eligible products and rebate amounts, visit dpandl.com/bizrebates or contact us at EnergyEfficiency@dplinc.com.

Eligible products and rebate values are subject to change and apply only to new equipment that replaces existing equipment or is part of a retrofit project. All DP&L energy programs are subject to Public Utilities Commission of Ohio rules and regulations.